



Certificate of Compliance

Certificate Number: LR 35579-332

Revision: LR 35579-456

Date Issued: August 26, 1999

Issued To: TAKAMISAWA ELECTRIC CO. LTD.
No 3-5, Higashi-Gotanda 2-chome
Shinagawa-ku, Tokyo 141
Japan

The products listed below are eligible to bear the CSA Mark.

Issued By: Erij P. Aggarwal, P. Eng.
For: Vancouver, BC Canada

Signature

CLASS

3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

PRODUCTS

Relays, open type with dust cover, single pole, single throw, Type JV with suffixes, rated 5A, 30V dc/250V ac res, 100,000 operations, 1/8 hp, 125/250V ac, 30,000 operations, pilot duty C300, 30,000 operations. Coils rated 3 to 48V dc.

Note: In the case of open type devices and equipment, the necessary enclosure is required to be provided by the equipment in which it is to be installed and the suitability of the combination is to be determined.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No 14-95 - Industrial Control Equipment

JR-90109

REV B/941104/DQD 507

Page 1/1