



Certificate of Compliance

Certificate Number: LR 35579-136

Revision: LR 35579-448

Date Issued: December 4, 1998

Issued To: TAKAMISAWA ELECTRIC CO., LTD.
No 3-5, Higashi-Gotanda 2-chome
Shinagawa-ku, Tokyo
Japan

The products listed below are eligible to bear the CSA Mark.

Issued By: Brij P. Aggarwal, P. Eng.
Vancouver, BC Canada

Signature

CLASS

3211 04 - INDUSTRIAL CONTROL EQUIPMENT - Motor Conrollers - Magnetic

PRODUCTS

Relays, Types JY and JZ (with suffixes) and special Part No JY101-K, Open type, sealed, with dust cover, 1-pole, single throw contacts, max ratings as follows:

JR-89235

REV B/941104/DQD 507

Page 1/2



Certificate of Compliance

Certificate Number: LR 35579-136

Revision: LR 35579-448

Date Issued: December 4, 1998

Type	Suffix	24V dc	30V dc	125V ac	250V ac	Pilot Duty
JY, JZ	-	-	3A	1/10hp	3A res, 1/10hp	D150
JY, JZ	H	-	5A	1/8hp	5A res, 1/8hp	C150, C300
JY101K	-	-	5A	1/8hp	5A res, 1/8hp	C150, C300
JY	A	-	5A	5A res, 1/8hp	5A res, 1/8hp	C150
JY	W or WE	-	3A	1/10hp	3A res, 1/10hp	D150
JY	WL	1A	-	0.5A res	-	-

Coils: Type JY and JZ, 4.5 to 48V dc; Special part No, JY101-K, 23.5V dc

Notes:

1. Suffix letters and/or numbers added to the type designation indicate electrical ratings and type of construction.
2. These relays are Certified as components for use only in other Certified equipment where the suitability of the combination is determined by the Canadian Standards Association.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No 14-95 - Industrial Control Equipment