



Certificate of Compliance

Certificate Number: LR 35579-222

Revision: LR 35579-444

Date Issued: September 11, 1998

Issued To: YAKAMISAWA ELECTRIC CO., LTD.
No. 3-5, Higashi-Gotanda 2-chome
Shinagawa-ku, Tokyo 141
Japan

The products listed below are eligible to bear the CSA Mark.

Issued By: Brij P. Aggarwal, P. Eng.
Vancouver, BC Canada

Signature

CLASS

3211 04 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Magnetic

PRODUCTS

Relays, Type VE, sealed open type with dust cover, 1-pole, single or double throw contact. Coil: 5 to 48V dc, max ratings:

Suffixes	Contact	30V dc	125V ac	250V ac	Pilot Duty
H, HE, HS	N.C.	5A res	1/14 hp	3A res, 1/14 hp	D300
HSE	N.O.	5A res	1/14 hp	5A res, 1/14 hp	D300
HM, HME	N.O.	5A res	1/12 hp	5A res, 1/12 hp	D300
HMS, HMSE					
H5, H55	N.C.	5A res	5A res, 1/14 hp	5A res, 1/14 hp	D300
	N.O.	5A res	5A res, 1/10 hp	5A res, 1/10 hp	D300
HMS, HM55	N.O.	5A res	1/10 hp	5A res, 1/10 hp	D300

JR-89356

REV B/941106/DQD 507

Page 1/2



Certificate of Compliance

Certificate Number: LR 35579-222

Revision: LR 35579-444

Date Issued: September 11, 1998

Notes:

1. Suffix letters and/or numbers added to type designation to form part number and indicate electrical rating and type of construction.
2. Open type relays are Certified as components for use only in other Certified equipment where the suitability of the combination is determined by the Canadian Standards Association.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 14-95 - Industrial Control Equipment