



Certificate of Compliance

Certificate Number: LR 35579-165

Revision: LR 35579-406

Date Issued: December 12, 1996

Issued To: TAKAMISAWA ELECTRIC CO., LTD.
No. 3-5, Higashi-Gotanda 2-chome
Shinagawa-ku, Tokyo 141
Japan

The products listed below are eligible to bear the CSA Mark.

Issued By: Yim Hui, P. Eng.
Director, Japan
Certification and Testing
Division

Signature

CLASS

3211 04 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Magnetic

PRODUCTS

Relays, Type VSB (with suffixes), open type with dust cover, spst and spdt, contacts rated: 16A, 30V dc; 16A, 250V ac (res); 1/3 hp, 125V ac/250V ac, C150 pilot duty; with suffix '5R' 17A (res), 125V ac; 16A, 30V dc; 16A, 250V ac(res); 1/3 hp, 125V ac/250V ac, C150 pilot duty, N.C; 1/2 hp, 125V/250V ac, B150 pilot duty, N.O; coil 3 to 100V dc.

Notes:

1. Open type devices are Certified as components for use only in other Certified equipment where the suitability of the combination is determined by the Canadian Standards Association.

JR-67519

REV B/941104/DQD 507

Page 1/2



Certificate of Compliance

Certificate Number: LR 35579-165

Revision: LR 35579-406

Date Issued: December 12, 1996

-
2. Suffix numbers and/or letters are added to type designation to denote relay/coil types, construction, etc.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 14-95 - Industrial Control Equipment