

1655 Scott Boulevard  
Santa Clara, CA 95050-4169  
United States Country Code (1)  
(408) 985-2400  
FAX No. (408) 296-3256  
<http://www.ul.com>



File E63614  
Project 99SC45157

April 21, 1999

REPORT  
ON  
COMPONENT - MOTOR CONTROLLERS, MAGNETIC

Fujitsu Takamisawa Component Ltd.  
Nagano, Japan

Copyright © 1999 Underwriters Laboratories Inc.

Underwriters Laboratories Inc. authorizes the above-named company to reproduce this Report provided it is reproduced in its entirety.

Underwriters Laboratories Inc. authorizes the above-named company to reproduce that portion of this Report consisting of this Cover Page through Page 2.

JR/CN:ncn  
SCDLS

A not-for-profit organization  
dedicated to public safety and  
committed to quality service

## DESCRIPTION

## PRODUCT COVERED:

Component - Magnetic, Motor Controllers, Model Series Type F6, with or without prefix FTR-, followed by A, followed by A, followed by 005 through 024, followed by Z, may or may not be followed by -01 through -99.

## GENERAL:

The devices are enclosed type magnetically operated, single-pole normally open contacts with single stable, one winding coil. These devices are provided with terminals for direct printed circuit mounting.

They are intended for use in industrial control equipment. Relay Type FTR-F6 is constructed of A Class 130 B Insulation Materials.

## RATINGS:

## Contact:

3 A, 30 dc, Resistive, 6000 cycles.  
3 A, 277 V ac, Resistive, 6000 cycles.  
1/10 hp, 250 V ac, 6000 cycles.  
1/10 hp, 125 V ac, 6000 cycles.  
1/8 hp, 277 V ac, 6000 cycles  
Pilot Duty, Code D300, 6000 cycles

Coil: 5-24 V dc

## NOMENCLATURE:

The significance of the alphanumeric marking system is explained as follows:

<u>FTR-F6</u>	<u>A</u>	<u>A</u>	<u>005</u>	<u>Z</u>	<u>-01</u>
I	II	III	IV	V	VI

- I. Basic Designation - Indicates type number, with or without prefix FTR.
- II. Contact configuration A - 1 Form A
- III. Coil Sensibility A - General
- IV. Coil rated voltage 005 through 024 - 5 through 24 V dc
- V. Contact material.
  - Z - Copper Base overlaid with silver nickel overlaid with gold.
- VI. Minor construction variation 01 - 99
  - A) Variation of coil resistance.
  - B) Variation of pickup voltage, non-pick up voltage, dropout voltage or hold voltage.
  - C) Variation of operate or release time.
  - D) Variation of dielectric strength.

## ENGINEERING CONSIDERATIONS (NOT FOR FIELD REPRESENTATIVE'S USE):

Use - For use only in (or with) complete equipment where the acceptability of the combination is determined by Underwriters Laboratories Inc.

## Conditions of Acceptability:

1. The coil and contact terminals are not suitable for field wiring.
2. Relays should be mounted in appropriate enclosures.